

## SECTION 3

### 3.10 PIPE MATERIAL:

All service lines supplying water from Denver Water's system shall conform to one of the following specifications. Plastic pipe is not an acceptable service line material.

- A. Seamless Copper Tube of the type designated as Type K; soft, in the industry shall be used for service lines 3/4 inch through 2 inches and may be used for 3 inch service lines.
- B. Ductile Iron Pipe conforming to MS-1 may be used for 3 inch service lines, and shall be used for all service lines larger than 3 inches.